


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 1002361	Main Street: DAVID_TAYLOR_DR	Cross Street: N/A	Location: W
ADA ID: 83D8DDC5F4B0	Overall Compliance: No	Severity Score: 35	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Remove & Replace Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.2, 810.2.4,
810.3, R302, R308.1.1.1, R308.1.1.2,
R404.1, R404.2, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	76.0
No	Boarding Area Length (in)	72.0
No	Boarding Area Slope %	2.2
No	Boarding Area XSlope %	2.9
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	96.0
No	Clear Floor Space Length (in)	47.5
No	Clear Floor Space Slope %	2.7
Yes	Clear Floor Space XSlope %	1.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	98.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 44235

CATS Stop Description: David Taylor Dr @ 9711 (Clarke America)

CATS Route ID: 50, 54

CATS Route Name: Multiple

Total Cost: \$ 1750.00

