

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 7035	Main Street: OLD_MT_HOLLY_RD	Cross Street: WINDY_VALLEY_DR	Location: S
ADA ID: 84726993395B	Overall Compliance: No	Severity Score: 35	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.4, 810.3, R302,
R308.1.1.2, R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	82.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	2.5
Yes	Boarding Area XSlope %	0.9
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	1.1
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	45.0
Yes	Clear Floor Space Length (in)	48.0
Yes	Clear Floor Space Slope %	0.9
No	Clear Floor Space XSlope %	2.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 44390

CATS Stop Description: Old Mt Holly Rd & Windy Valley Dr

CATS Route ID: 1

CATS Route Name: Mt Holly Valleydale

Total Cost: \$ 3750.00

