


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 14053	Main Street: AMAY_JAMES_AV	Cross Street: WEST_BV	Location: N
ADA ID: 84F4CCEF3DDF	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,
R302.6, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	194.0
Yes	Boarding Area Length (in)	127.0
No	Boarding Area Slope %	2.4
No	Boarding Area XSlope %	2.2
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	1.8
No	PAR 1 XSlope %	3.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
No	PAR 2 Slope %	2.2
No	PAR 2 XSlope %	2.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	227.0
N/A	Clear Floor Space Length (in)	73.0
N/A	Clear Floor Space Slope %	2.9
N/A	Clear Floor Space XSlope %	0.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 34450

CATS Stop Description: **West Blvd & Amay James Ave**

CATS Route ID: 10

CATS Route Name: **West Boulevard**

Total Cost: \$ 2150.00

