


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10036889	Main Street: S_MCDOWELL_ST	Cross Street: N/A	Location: W
ADA ID: 8648688C2D3F	Overall Compliance: No	Severity Score: 60	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.2, 810.2.3, R302, R302.6,
R308.1.1.1**

CATS Stop ID: **25550**

CATS Stop Description: **McDowell St & Martin Luther King Jr Blvd**

CATS Route ID: **20, 6**

CATS Route Name: **Multiple**

Total Cost: \$ **1450.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	51.0
No	Boarding Area Length (in)	68.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	0.5
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
No	PAR 1 Slope %	2.1
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	2.0
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	0.8
N/A	Clear Floor Space XSlope %	0.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	86.0
N/A	Bench?	No
Yes	Protruding Objects?	No

