


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10035273	Main Street: QUEENS_RD	Cross Street: N/A	Location: W
ADA ID: 888BF5B92F45	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,
R302.6, R308.1.1.1, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	54.0
Yes	Boarding Area Length (in)	163.0
No	Boarding Area Slope %	6.8
No	Boarding Area XSlope %	6.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
Yes	PAR 1 Slope %	3.9
Yes	PAR 1 XSlope %	0.4
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	59.0
Yes	PAR 2 Slope %	4.7
No	PAR 2 XSlope %	2.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.0
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	60.0
N/A	Clear Floor Space Length (in)	67.0
N/A	Clear Floor Space Slope %	4.1
N/A	Clear Floor Space XSlope %	4.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 23250

CATS Stop Description: Queens Rd @ Queens Towers Apts

CATS Route ID: 20

CATS Route Name: Queens Road

Total Cost: \$ 1450.00

