


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033470	Main Street: OLD_PINEVILLE_RD	Cross Street: N/A	Location: W
ADA ID: 8898A8640FD3	Overall Compliance: No	Severity Score: 5	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

N/A

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.5
Yes	Boarding Area XSlope %	0.3
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	57.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	1.5
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	57.0
Yes	PAR 2 Slope %	0.4
Yes	PAR 2 XSlope %	1.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.7
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	71.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	0.9
Yes	Clear Floor Space XSlope %	0.5
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: **46010**

CATS Stop Description: **Woodlawn Station**

CATS Route ID: **24**

CATS Route Name: **Nations Ford**

Total Cost: \$ **2000.00**

