


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 14426	Main Street: WEDDINGTON_AV	Cross Street: RANIER_AV	Location: SW
ADA ID: 893137621CBC	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.3, 810.2.4, R302,
R302.3, R302.6, R308.1.1.2**

CATS Stop ID: **08080**
CATS Stop Description: **7th St & Bascom St**
CATS Route ID: **27**
CATS Route Name: **Monroe Road**

Total Cost: \$ **1450.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	71.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	2.4
Yes	Boarding Area XSlope %	0.7
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	106.0
Yes	PAR 1 Slope %	2.0
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	46.5
Yes	PAR 2 Slope %	1.5
No	PAR 2 XSlope %	4.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.5
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	No
Yes	Protruding Objects?	No

