


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10844	Main Street: W_5TH_ST	Cross Street: FRAZIER_AV	Location: NE
ADA ID: 897B03AC6C89	Overall Compliance: No	Severity Score: 60	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk Connection to
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

810.2.2, 810.2.3, R302, R308.1.1.1

CATS Stop ID: **33210**
CATS Stop Description: **5th St & Frazier Ave**
CATS Route ID: **1, 7**
CATS Route Name: **Multiple**

Total Cost: \$ **1500.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	96.0
No	Boarding Area Length (in)	50.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	7.7
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	8.0
Yes	PAR 1 XSlope %	1.3
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	8.5
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

