


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                        |                                         |              |
|-----------------------------------------|------------------------|-----------------------------------------|--------------|
| Intersection ID: 10025347               | Main Street: E_7TH_ST  | Cross Street: N/A                       | Location: SW |
| ADA ID: 8B859211F9D8                    | Overall Compliance: No | Severity Score: 5                       |              |
| Codes/Mitigation Info/Possible Solution |                        | Field Measurements/Component Compliance |              |



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Remove or Relocate  
Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.2, 810.2.3, R302, R302.5,  
R302.6, R308.1.1.1**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 60.0 |
| No         | Boarding Area Length (in)       | 65.0 |
| Yes        | Boarding Area Slope %           | 1.5  |
| Yes        | Boarding Area XSlope %          | 1.2  |
| No         | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 59.0 |
| Yes        | PAR 1 Slope %                   | 0.6  |
| No         | PAR 1 XSlope %                  | 2.1  |
| N/A        | PAR 1 XSlope Location           | Perp |
| No         | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 59.0 |
| Yes        | PAR 2 Slope %                   | 0.5  |
| No         | PAR 2 XSlope %                  | 3.3  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 3.4  |
| N/A        | Shelter                         | No   |
| Yes        | Clear Floor Space               | Yes  |
| N/A        | Clear Floor Space Shelter       | No   |
| Yes        | Clear Floor Space Width (in)    | 42.0 |
| Yes        | Clear Floor Space Length (in)   | 60.0 |
| Yes        | Clear Floor Space Slope %       | 0.5  |
| Yes        | Clear Floor Space XSlope %      | 0.0  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 87.0 |
| N/A        | Bench?                          | Yes  |
| No         | Protruding Objects?             | Yes  |

CATS Stop ID: **45660**

CATS Stop Description: **7th St & Charlottetowne Ave**

CATS Route ID: **27**

CATS Route Name: **Monroe Road**

Total Cost: \$ **4150.00**

