


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10032526	Main Street: N_CHURCH_ST	Cross Street: N/A	Location: W
ADA ID: 8BA637D64D64	Overall Compliance: No	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space.

Surveyor Notes:

BOARDING WIDTH 254.0

PROW/ADA:

402.2, 810.2.3, 810.3, R302, R302.5, R404.1

CATS Stop ID: **37410**
 CATS Stop Description: **Church St & 9th St**
 CATS Route ID: **11, 21**
 CATS Route Name: **Multiple**

Total Cost: \$ **1150.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	254.0
Yes	Boarding Area Length (in)	120.0
Yes	Boarding Area Slope %	1.9
Yes	Boarding Area XSlope %	0.2
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.4
No	PAR 1 XSlope %	2.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.2
Yes	PAR 2 XSlope %	1.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.2
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

