


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10017955	Main Street: THE_PLAZA	Cross Street: N/A	Location: S
ADA ID: 8D3300A72C3E	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

CLEAR FLOOR SPACE MEASURED WITHIN PAR AREA

PROW/ADA:

402.2, 810.2.3, R302, R302.5

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	76.0
Yes	Boarding Area Length (in)	103.0
Yes	Boarding Area Slope %	1.8
Yes	Boarding Area XSlope %	0.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.5
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
No	PAR 2 Slope %	5.1
Yes	PAR 2 XSlope %	0.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.0
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	65.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	1.2
Yes	Clear Floor Space XSlope %	1.6
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 31560

CATS Stop Description: The Plaza & Plaza Walk Dr

CATS Route ID: 3

CATS Route Name: The Plaza

Total Cost: \$ 2700.00

