


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10014462	Main Street: TIPPERARY_PL	Cross Street: N/A	Location: N
ADA ID: 8D5326D6853F	Overall Compliance: No	Severity Score: 35	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove or Relocate
Protruding Objects/Obstructions.
Provide Transit Stop Sign.**

Surveyor Notes:

**BUS STOP LISTED IN GOOGLE
MAPS, NO SIGN OR CATS ID**

PROW/ADA:

**402.2, 703.5.1, 810.2.2, 810.2.3, R302,
R302.5, R308.1.1.1, R410.6**

CATS Stop ID: 32370

CATS Stop Description: **Tipperary Pl & Milton Rd**

CATS Route ID: 23

CATS Route Name: **Shamrock Drive**

Total Cost: \$ 3950.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	60.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	0.1
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	54.0
Yes	PAR 1 Slope %	0.1
No	PAR 1 XSlope %	4.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	54.0
Yes	PAR 2 Slope %	1.0
Yes	PAR 2 XSlope %	1.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
No	Transit Sign?	No
N/A	Transit Sign Height (in)	N/A
N/A	Bench?	No
No	Protruding Objects?	Yes

