


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                             |                                         |             |
|-----------------------------------------|-----------------------------|-----------------------------------------|-------------|
| Intersection ID: -9999                  | Main Street: Sefton Park Rd | Cross Street: N/A                       | Location: S |
| ADA ID: 9060B2B9D882                    | Overall Compliance: No      | Severity Score: 10                      |             |
| Codes/Mitigation Info/Possible Solution |                             | Field Measurements/Component Compliance |             |



Possible Solutions:

**Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.3, R302, R302.5**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 60.0  |
| Yes        | Boarding Area Length (in)       | 96.0  |
| Yes        | Boarding Area Slope %           | 0.6   |
| Yes        | Boarding Area XSlope %          | 1.7   |
| Yes        | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 153.0 |
| Yes        | PAR 1 Slope %                   | 1.7   |
| Yes        | PAR 1 XSlope %                  | 0.6   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| No         | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 153.0 |
| No         | PAR 2 Slope %                   | 2.2   |
| Yes        | PAR 2 XSlope %                  | 1.7   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 0.7   |
| N/A        | Shelter                         | Yes   |
| Yes        | Clear Floor Space               | Yes   |
| N/A        | Clear Floor Space Shelter       | Yes   |
| Yes        | Clear Floor Space Width (in)    | 108.0 |
| Yes        | Clear Floor Space Length (in)   | 114.0 |
| Yes        | Clear Floor Space Slope %       | 0.2   |
| Yes        | Clear Floor Space XSlope %      | 1.3   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 96.0  |
| N/A        | Bench?                          | Yes   |
| No         | Protruding Objects?             | Yes   |

CATS Stop ID: 59500

CATS Stop Description: Cornelius Park & Ride

CATS Route ID: 48x, 97

CATS Route Name: Multiple

Total Cost: \$ 2700.00

