


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033733	Main Street: OUTLETS_BV	Cross Street: DESIGNER_DR	Location: SE
ADA ID: 9237E251EF4F	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.2, 810.2.3,
810.3, R302, R302.5, R308.1.1.1,
R404.1, R404.2, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	70.0
Yes	Boarding Area Slope %	1.2
Yes	Boarding Area XSlope %	1.9
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	70.0
Yes	PAR 1 Slope %	1.1
No	PAR 1 XSlope %	2.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	70.0
No	PAR 2 Slope %	2.6
Yes	PAR 2 XSlope %	2.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.8
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	48.0
No	Clear Floor Space Length (in)	46.0
Yes	Clear Floor Space Slope %	1.2
No	Clear Floor Space XSlope %	3.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	105.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 52000

CATS Stop Description: Outlets Bv & Designer Dr

CATS Route ID: 55, 56

CATS Route Name: Multiple

Total Cost: \$ 2650.00

