


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 43509	Main Street: MULBERRY_POND_DR	Cross Street: TUCKASEEGEE_RD	Location: S
ADA ID: 95E3D75598CA	Overall Compliance: No	Severity Score: 100	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Provide Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2, R302, R308.1.1

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	3.8
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	No
No	Protruding Objects?	Yes

CATS Stop ID: 32760

CATS Stop Description: Tuckaseegee Rd & Mulberry Pond Dr

CATS Route ID: 8

CATS Route Name: Tuckaseegee Road

Total Cost: \$ 3200.00

