


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 22521	Main Street: OAK_MEADOW_CT	Cross Street: SHARON_LAKES_RD	Location: N
ADA ID: 95F746E01B2C	Overall Compliance: No	Severity Score: 30	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 402.2, 403.5.1, 810.2.3, 810.3, R302, R302.3, R302.5, R404.1, R404.2

CATS Stop ID: **45200**

CATS Stop Description: **Sharon Lakes Rd & Oak Meadow Ct**

CATS Route ID: **12**

CATS Route Name: **South Boulevard**

Total Cost: **\$ 3900.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	62.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	4.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.5
Yes	PAR 1 Slope %	4.8
Yes	PAR 1 XSlope %	0.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	47.5
No	PAR 2 Slope %	6.6
Yes	PAR 2 XSlope %	1.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.1
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	69.0
Yes	Clear Floor Space Length (in)	68.0
No	Clear Floor Space Slope %	2.9
No	Clear Floor Space XSlope %	5.6
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

