


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                             |                                         |             |
|-----------------------------------------|-----------------------------|-----------------------------------------|-------------|
| Intersection ID: 10013202               | Main Street: STATESVILLE_RD | Cross Street: N/A                       | Location: E |
| ADA ID: 984943193136                    | Overall Compliance: N/A     | Severity Score: 10                      |             |
| Codes/Mitigation Info/Possible Solution |                             | Field Measurements/Component Compliance |             |



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

CATS Stop ID: **46689**  
 CATS Stop Description: **Statesville Rd & Sunset Rd**  
 CATS Route ID: **7**  
 CATS Route Name: **Beatties Ford**

Total Cost: **\$0.00**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| N/A        | Boarding Area                   | Yes   |
| N/A        | Boarding Area Width (in)        | 68.0  |
| N/A        | Boarding Area Length (in)       | 96.0  |
| N/A        | Boarding Area Slope %           | 2.6   |
| N/A        | Boarding Area XSlope %          | 1.5   |
| N/A        | PAR 1 Exist?                    | Yes   |
| N/A        | PAR 1 Width (in)                | 60.0  |
| N/A        | PAR 1 Slope %                   | 0.1   |
| N/A        | PAR 1 XSlope %                  | 0.7   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| N/A        | PAR 2 Exist?                    | Yes   |
| N/A        | PAR 2 Width (in)                | 60.0  |
| N/A        | PAR 2 Slope %                   | 0.3   |
| N/A        | PAR 2 XSlope %                  | 0.7   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| N/A        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 0.4   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | Yes   |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | 118.0 |
| N/A        | Clear Floor Space Length (in)   | 48.0  |
| N/A        | Clear Floor Space Slope %       | 0.2   |
| N/A        | Clear Floor Space XSlope %      | 0.8   |
| N/A        | Alcove Condition?               | No    |
| N/A        | Transit Sign?                   | Yes   |
| N/A        | Transit Sign Height (in)        | 94.0  |
| N/A        | Bench?                          | No    |
| N/A        | Protruding Objects?             | Yes   |

