


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10012683	Main Street: N_DAVIDSON_ST	Cross Street: N/A	Location: W
ADA ID: 986A28906824	Overall Compliance: No	Severity Score: 20	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.2, 810.2.3, 810.3,
R302, R302.5, R302.6, R308.1.1.1,
R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	59.0
Yes	Boarding Area Length (in)	113.5
Yes	Boarding Area Slope %	0.6
Yes	Boarding Area XSlope %	1.9
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	107.0
No	PAR 1 Slope %	2.3
Yes	PAR 1 XSlope %	0.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
No	PAR 2 Slope %	2.6
Yes	PAR 2 XSlope %	0.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	74.0
Yes	Clear Floor Space Length (in)	107.0
No	Clear Floor Space Slope %	2.3
No	Clear Floor Space XSlope %	2.6
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 17500

CATS Stop Description: Davidson St & 25th St

CATS Route ID: 23

CATS Route Name: Shamrock Drive

Total Cost: \$ 4650.00

