


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040786	Main Street: W_TYVOLA_RD	Cross Street: POTOMAC_RIVER_PY	Location: N
ADA ID: 994B49DE3063	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

**MEASURED PAR 1 AND 2 ON RAMP
LEADING TO BOARDING AREA**

PROW/ADA:

**402.2, 810.2.2, 810.2.3, R302, R302.5,
R302.6, R308.1.1.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	116.0
No	Boarding Area Length (in)	78.0
Yes	Boarding Area Slope %	1.5
Yes	Boarding Area XSlope %	2.1
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	58.0
No	PAR 1 Slope %	4.8
No	PAR 1 XSlope %	3.0
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	61.0
Yes	PAR 2 Slope %	2.5
Yes	PAR 2 XSlope %	1.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.6
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 46641

CATS Stop Description: Tyvola Rd & City Park Dr

CATS Route ID: 60

CATS Route Name: Tyvola Road

Total Cost: \$ 1450.00

