


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10032177	Main Street: MORRIS_FIELD_DR	Cross Street: N/A	Location: N
ADA ID: 99D7B7844050	Overall Compliance: No	Severity Score: 20	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,
R302.6, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	136.0
No	Boarding Area Slope %	2.7
No	Boarding Area XSlope %	2.4
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
Yes	PAR 1 Slope %	1.8
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	59.0
No	PAR 2 Slope %	3.5
No	PAR 2 XSlope %	3.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.9
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	89.0
Yes	Clear Floor Space Length (in)	54.4
Yes	Clear Floor Space Slope %	1.0
Yes	Clear Floor Space XSlope %	1.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 20282

CATS Stop Description: **Morris Field Dr & Airport Center Pkwy**

CATS Route ID: 235

CATS Route Name: **Goodwill / Amay James**

Total Cost: \$ 1450.00

