


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10034835	Main Street: PRESSLEY_RD	Cross Street: N/A	Location: N
ADA ID: 9D7D4046FBBF	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	101.0
Yes	Boarding Area Slope %	0.6
Yes	Boarding Area XSlope %	1.2
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	1.8
Yes	PAR 1 XSlope %	0.4
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
No	PAR 2 Slope %	3.3
Yes	PAR 2 XSlope %	1.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.7
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	48.0
Yes	Clear Floor Space Length (in)	59.0
Yes	Clear Floor Space Slope %	1.8
Yes	Clear Floor Space XSlope %	1.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	98.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 21990

CATS Stop Description: Pressley Rd & Charlotte Park Dr

CATS Route ID: 12

CATS Route Name: South Boulevard

Total Cost: \$ 2700.00

