


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                        |                                         |             |
|-----------------------------------------|------------------------|-----------------------------------------|-------------|
| Intersection ID: -9999                  | Main Street: N Main St | Cross Street: N/A                       | Location: W |
| ADA ID: A22FB9BB7416                    | Overall Compliance: No | Severity Score: 10                      |             |
| Codes/Mitigation Info/Possible Solution |                        | Field Measurements/Component Compliance |             |



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Remove or Relocate  
Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,  
R302.6, R308.1.1.2**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 60.0 |
| Yes        | Boarding Area Length (in)       | 96.0 |
| No         | Boarding Area Slope %           | 3.1  |
| Yes        | Boarding Area XSlope %          | 1.4  |
| No         | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 60.0 |
| Yes        | PAR 1 Slope %                   | 1.4  |
| No         | PAR 1 XSlope %                  | 3.1  |
| N/A        | PAR 1 XSlope Location           | Perp |
| No         | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 60.0 |
| Yes        | PAR 2 Slope %                   | 0.8  |
| No         | PAR 2 XSlope %                  | 2.4  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 1.8  |
| N/A        | Shelter                         | Yes  |
| Yes        | Clear Floor Space               | Yes  |
| N/A        | Clear Floor Space Shelter       | Yes  |
| Yes        | Clear Floor Space Width (in)    | 32.0 |
| Yes        | Clear Floor Space Length (in)   | 72.0 |
| Yes        | Clear Floor Space Slope %       | 0.1  |
| Yes        | Clear Floor Space XSlope %      | 1.5  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 88.0 |
| N/A        | Bench?                          | Yes  |
| No         | Protruding Objects?             | Yes  |

CATS Stop ID: **40220**

CATS Stop Description: **Main St & Railroad St**

CATS Route ID: **77x, 97, 99**

CATS Route Name: **Multiple**

Total Cost: \$ **4150.00**

