


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 5117	Main Street: SPECTOR_DR	Cross Street: STATESVILLE_RD	Location: E
ADA ID: A2371A9B1D4A	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

BROKEN CONC ON BOARDING

PROW/ADA:

810.2.2, R308.1.1.1

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	59.0
Yes	Boarding Area Length (in)	120.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	0.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	61.0
Yes	PAR 1 Slope %	1.2
Yes	PAR 1 XSlope %	0.2
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.2
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 45839

CATS Stop Description: Statesville Rd & Spector Dr

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 750.00

