


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10011222	Main Street: MALLARD_CREEK_RD	Cross Street: N/A	Location: E
ADA ID: A6518AC5A3BF	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.2, 810.2.3,
810.2.4, 810.3, R302, R302.5,
R308.1.1.1, R308.1.1.2, R404.1,
R404.2**

CATS Stop ID: **40080**

CATS Stop Description: **Mallard Creek Rd & Mallard Square Ln**

CATS Route ID: **22**

CATS Route Name: **Graham Street**

Total Cost: \$ **3950.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	57.0
Yes	Boarding Area Length (in)	113.0
No	Boarding Area Slope %	17.7
No	Boarding Area XSlope %	2.5
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.5
No	PAR 1 XSlope %	2.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.2
Yes	PAR 2 XSlope %	1.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.0
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	44.0
Yes	Clear Floor Space Length (in)	64.0
No	Clear Floor Space Slope %	2.3
Yes	Clear Floor Space XSlope %	0.5
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	88.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

