


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10029942	Main Street: LAKEVIEW_RD	Cross Street: N/A	Location: S
ADA ID: A65537A3009F	Overall Compliance: No	Severity Score: 65	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.4, R302, R308.1.1.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	120.0
Yes	Boarding Area Length (in)	120.0
No	Boarding Area Slope %	3.0
Yes	Boarding Area XSlope %	0.4
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.0
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	87.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: **45769**

CATS Stop Description: **Lakeview Rd & Potomac Blvd**

CATS Route ID: **7**

CATS Route Name: **Beatties Ford**

Total Cost: \$ **1250.00**

