


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 22219	Main Street: PARK_RD	Cross Street: SETH_THOMAS_RD	Location: NW
ADA ID: A8D15B2BFDA3	Overall Compliance: No	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2.2, R308.1.1.1

CATS Stop ID: 21160

CATS Stop Description: **Park Rd & Seth Thomas Rd**

CATS Route ID: 19

CATS Route Name: **Park Road**

Total Cost: \$ 750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	64.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	0.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	58.0
Yes	PAR 1 Slope %	1.5
Yes	PAR 1 XSlope %	0.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	58.0
Yes	PAR 2 Slope %	1.7
Yes	PAR 2 XSlope %	0.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.2
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	No
Yes	Protruding Objects?	No

