


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10036954	Main Street: S_TRYON_ST	Cross Street: N/A	Location: S
ADA ID: A99432319237	Overall Compliance: No	Severity Score: 15	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 402.2, 810.2.3, 810.3, R302, R302.5, R302.6, R404.1, R404.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	79.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	2.0
Yes	Boarding Area XSlope %	2.9
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	192.0
Yes	PAR 1 Slope %	2.5
No	PAR 1 XSlope %	3.0
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	192.0
Yes	PAR 2 Slope %	2.6
No	PAR 2 XSlope %	2.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.5
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	79.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	2.0
No	Clear Floor Space XSlope %	2.9
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 25641

CATS Stop Description: Tryon St & Trade St

CATS Route ID: 11, 21

CATS Route Name: Multiple

Total Cost: \$ 3900.00

