


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033132	Main Street: NORTHLAKE_MALL_DR	Cross Street: N/A	Location: S
ADA ID: AAA01C2826E6	Overall Compliance: No	Severity Score: 5	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

N/A

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	66.0
Yes	Boarding Area Length (in)	144.0
Yes	Boarding Area Slope %	1.3
Yes	Boarding Area XSlope %	1.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	71.0
Yes	PAR 1 Slope %	1.1
Yes	PAR 1 XSlope %	1.3
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	71.0
Yes	PAR 2 Slope %	1.7
Yes	PAR 2 XSlope %	1.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	68.0
Yes	Clear Floor Space Length (in)	63.0
Yes	Clear Floor Space Slope %	1.6
Yes	Clear Floor Space XSlope %	1.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	88.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 45813

CATS Stop Description: Northlake Mall (2nd Stop)

CATS Route ID: 53x, 7, 99

CATS Route Name: Multiple

Total Cost: \$ 2000.00

