


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041435	Main Street: WESTINGHOUSE_BV	Cross Street: N/A	Location: E
ADA ID: AC35696428BC	Overall Compliance: No	Severity Score: 80	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Provide Sidewalk Connection to Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2, 810.2.3, R302, R308.1.1

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.1
Yes	PAR 1 XSlope %	1.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.2
Yes	PAR 2 XSlope %	1.7
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.8
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	88.5
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 34970

CATS Stop Description: **Westinghouse Blvd & South Commerce Blvd**

CATS Route ID: 55

CATS Route Name: **Westinghouse**

Total Cost: \$ 1450.00

