


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10025297	Main Street: E_4TH_ST	Cross Street: N/A	Location: NE
ADA ID: AE16FE4B4552	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	72.0
Yes	Boarding Area Length (in)	144.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	4.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	144.0
Yes	PAR 1 Slope %	4.1
No	PAR 1 XSlope %	2.9
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	144.0
Yes	PAR 2 Slope %	3.7
Yes	PAR 2 XSlope %	1.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	4.7
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: **45768**

CATS Stop Description: **4th St & McDowell St**

CATS Route ID: **14, 15, 20, 41x, 48x, 53x, 6, 61x, 62x, 74x, 77x, 82x, 85x, 88x**

CATS Route Name: **Multiple**

Total Cost: \$ **700.00**

