Access Compliance Report
Public Rights-of-Way
(Transit Stops)

Intersection ID: 10032959 **Main Street:** NEW_RENAISSANCE_WY **Cross Street:** N/A **Location:** W

ADA ID: AF762897D3BC **Overall Compliance:** No **Severity Score:** 15

Codes/Mitigation Info/Possible Solution



Possible Solutions:

Remove & Replace Boarding Area. Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 402.2, 810.2.2, 810.2.3, 810.2.4, 810.3, R302, R302.6, R308.1.1.1, R308.1.1.2, R404.1, R404.2

CATS Stop ID: **40000**

CATS Stop Description: **New Renaissance Way & Burnette Ave**

CATS Route ID: **10**

CATS Route Name: **West Boulevard** Total Cost: **$ 3950.00**

Field Measurements/Component Compliance

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	59.0
Yes	Boarding Area Length (in)	134.5
Yes	Boarding Area Slope %	0.5
No	Boarding Area XSlope %	2.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	71.0
Yes	PAR 1 Slope %	2.0
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	71.0
Yes	PAR 2 Slope %	1.9
No	PAR 2 XSlope %	3.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.1
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	94.0
Yes	Clear Floor Space Length (in)	58.5
No	Clear Floor Space Slope %	3.1
No	Clear Floor Space XSlope %	2.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes