


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10031996	Main Street: MONROE_RD	Cross Street: COVEDALE_DR	Location: E
ADA ID: B092CA137B2E	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.2, 810.2.3,
810.3, R302, R302.5, R308.1.1.1,
R404.1, R404.2, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	67.0
No	Boarding Area Length (in)	60.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	1.3
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.3
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
No	PAR 2 Slope %	2.9
Yes	PAR 2 XSlope %	1.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.8
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	90.5
No	Clear Floor Space Length (in)	26.0
Yes	Clear Floor Space Slope %	0.1
No	Clear Floor Space XSlope %	2.9
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 16510

CATS Stop Description: **Monroe Rd & Covedale Dr**

CATS Route ID: 27, 65x

CATS Route Name: **Multiple**

Total Cost: \$ 3950.00

