


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041433	Main Street: WESTINGHOUSE_BV	Cross Street: N/A	Location: E
ADA ID: B2561C59A19C	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2.2, R308.1.1.1

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	49.0
Yes	Boarding Area Length (in)	120.0
Yes	Boarding Area Slope %	1.8
Yes	Boarding Area XSlope %	0.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.9
Yes	PAR 1 XSlope %	1.1
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.4
Yes	PAR 2 XSlope %	1.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.0
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	214.0
N/A	Clear Floor Space Length (in)	71.0
N/A	Clear Floor Space Slope %	0.8
N/A	Clear Floor Space XSlope %	0.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 34940

CATS Stop Description: **Westinghouse Blvd @ 1200**

CATS Route ID: 55

CATS Route Name: **Westinghouse**

Total Cost: \$ 750.00

