

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 12983	Main Street: E_TRADE_ST	Cross Street: N_MYERS_ST	Location: E
ADA ID: B70BC6B00B05	Overall Compliance: No	Severity Score: 55	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

NO CATS ID LISTED

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,
R302.5, R302.6, R308.1.1.1,
R308.1.1.2**

CATS Stop ID: **N/A**
CATS Stop Description: **N/A**
CATS Route ID: **87**
CATS Route Name: **CityLYNX Connector**

Total Cost: \$ **2150.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	53.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.2
No	Boarding Area XSlope %	4.3
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	95.0
No	PAR 1 Slope %	4.6
Yes	PAR 1 XSlope %	1.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	95.0
No	PAR 2 Slope %	4.7
Yes	PAR 2 XSlope %	0.7
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	No
Yes	Protruding Objects?	No

