


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                           |                                         |              |
|-----------------------------------------|---------------------------|-----------------------------------------|--------------|
| Intersection ID: 10031842               | Main Street: MINTWORTH_AV | Cross Street: N/A                       | Location: SW |
| ADA ID: BBBBFD89B60                     | Overall Compliance: No    | Severity Score: 80                      |              |
| Codes/Mitigation Info/Possible Solution |                           | Field Measurements/Component Compliance |              |



Possible Solutions:

**Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2, 810.2.3, R302, R302.5, R308.1.1**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| No         | Boarding Area                   | No   |
| N/A        | Boarding Area Width (in)        | N/A  |
| N/A        | Boarding Area Length (in)       | N/A  |
| N/A        | Boarding Area Slope %           | N/A  |
| N/A        | Boarding Area XSlope %          | N/A  |
| No         | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 72.0 |
| Yes        | PAR 1 Slope %                   | 1.3  |
| No         | PAR 1 XSlope %                  | 2.2  |
| N/A        | PAR 1 XSlope Location           | Perp |
| N/A        | PAR 2 Exist?                    | No   |
| N/A        | PAR 2 Width (in)                | N/A  |
| N/A        | PAR 2 Slope %                   | N/A  |
| N/A        | PAR 2 XSlope %                  | N/A  |
| N/A        | PAR 2 XSlope Location           | N/A  |
| No         | Boarding Area Connected to PAR? | No   |
| N/A        | Road Slope %                    | 1.5  |
| N/A        | Shelter                         | No   |
| N/A        | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 92.0 |
| N/A        | Bench?                          | No   |
| Yes        | Protruding Objects?             | No   |

CATS Stop ID: **46406**

CATS Stop Description: **Mintworth Ave & Margaret Wallace Rd**

CATS Route ID: **52x**

CATS Route Name: **Idlewild Express**

Total Cost: \$ **1400.00**

