


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10012387	Main Street: N_TRYON_ST	Cross Street: OWEN_BV	Location: W
ADA ID: BBE9583C0DEF	Overall Compliance: No	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

810.3, R404.1

CATS Stop ID: **60291**

CATS Stop Description: **Tryon St & Owen Blvd**

CATS Route ID: **11, 211**

CATS Route Name: **Multiple**

Total Cost: \$ **450.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	108.0
Yes	Boarding Area Length (in)	102.0
Yes	Boarding Area Slope %	1.7
Yes	Boarding Area XSlope %	0.3
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	96.0
Yes	PAR 1 Slope %	0.6
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	96.0
Yes	PAR 2 Slope %	1.8
Yes	PAR 2 XSlope %	0.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.5
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

