

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033922	Main Street: PARK_RD	Cross Street: N/A	Location: W
ADA ID: C16FF6F28BFB	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

**GRADE BREAK IN BOARDING
AREA**

PROW/ADA:

810.2.4, R308.1.1.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	13.4
Yes	Boarding Area XSlope %	1.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	61.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	1.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	61.0
Yes	PAR 2 Slope %	0.4
Yes	PAR 2 XSlope %	1.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	46.0
Yes	Clear Floor Space Length (in)	48.0
Yes	Clear Floor Space Slope %	0.2
Yes	Clear Floor Space XSlope %	1.7
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 20540

CATS Stop Description: Park Rd & Charlotte Dr

CATS Route ID: 19

CATS Route Name: Park Road

Total Cost: \$ 2750.00

