


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10014422	Main Street: CENTRAL_AV	Cross Street: WILLOW_PARK_DR	Location: S
ADA ID: C8BC032BF420	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5

CATS Stop ID: 05550

CATS Stop Description: Central Ave & Rosehaven Dr

CATS Route ID: 17, 9

CATS Route Name: Multiple

Total Cost: \$ 700.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	150.0
Yes	Boarding Area Slope %	2.0
Yes	Boarding Area XSlope %	0.7
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
Yes	PAR 1 Slope %	0.4
No	PAR 1 XSlope %	2.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	72.0
Yes	PAR 2 Slope %	0.2
Yes	PAR 2 XSlope %	1.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.2
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	70.0
Yes	Clear Floor Space Length (in)	64.0
Yes	Clear Floor Space Slope %	2.0
Yes	Clear Floor Space XSlope %	1.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

