

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10020098	Main Street: ASHLEY_RD	Cross Street: N/A	Location: SW
ADA ID: CA59D2F559BC	Overall Compliance: No	Severity Score: 10	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.2, 810.2.3, R302, R302.5,
R308.1.1.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	104.0
No	Boarding Area Length (in)	46.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	0.1
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.0
No	PAR 1 XSlope %	2.3
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.2
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	69.0
Yes	Clear Floor Space Length (in)	62.0
Yes	Clear Floor Space Slope %	0.4
Yes	Clear Floor Space XSlope %	0.1
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	89.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 00410

CATS Stop Description: **Ashley Rd & Alleghany St**

CATS Route ID: 2, 235, 34, 8

CATS Route Name: **Multiple**

Total Cost: \$ 1450.00

