


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10036868	Main Street: S_KINGS_DR	Cross Street: N/A	Location: W
ADA ID: CB1082E3EF84	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk Connection to
Boarding Area.**

Surveyor Notes:

**PAR MEASURES ON ASP BEHIND
BOARDING AREA**

PROW/ADA:

810.2.2, 810.2.3, R302, R308.1.1.1

CATS Stop ID: **25440**
CATS Stop Description: **Kings Dr & Baxter St**
CATS Route ID: **6**
CATS Route Name: **Kings Drive**

Total Cost: \$ **1500.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	241.0
No	Boarding Area Length (in)	66.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	1.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	193.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	0.3
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	193.0
Yes	PAR 2 Slope %	1.3
Yes	PAR 2 XSlope %	0.8
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.5
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

