


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10022636	Main Street: CARMEL_RD	Cross Street: N/A	Location: E
ADA ID: CCAEA1A8174E	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Provide Transit
Stop Sign.**

Surveyor Notes:

NO SIGN, CATS ID NOT LISTED

PROW/ADA:

**305.2, 402.2, 703.5.1, 810.2.2,
810.2.3, 810.2.4, 810.3, R302, R302.5,
R302.6, R308.1.1.1, R308.1.1.2,
R404.1, R404.2, R410.6**

CATS Stop ID: N/A

CATS Stop Description: N/A

CATS Route ID: N/A

CATS Route Name: N/A

Total Cost: \$ 3150.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	62.0
No	Boarding Area Length (in)	60.5
No	Boarding Area Slope %	3.6
Yes	Boarding Area XSlope %	1.0
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.5
Yes	PAR 1 Slope %	2.1
No	PAR 1 XSlope %	2.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.5
Yes	PAR 2 Slope %	2.1
No	PAR 2 XSlope %	3.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.6
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	47.0
Yes	Clear Floor Space Length (in)	63.0
No	Clear Floor Space Slope %	2.9
Yes	Clear Floor Space XSlope %	1.6
N/A	Alcove Condition?	No
No	Transit Sign?	No
N/A	Transit Sign Height (in)	N/A
N/A	Bench?	Yes
Yes	Protruding Objects?	No

