


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 52266	Main Street: N_TRYON_ST	Cross Street: BROOKSIDE_LN	Location: E
ADA ID: CF470CEE95F8	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, 810.3, R302, R302.5, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	121.0
Yes	Boarding Area Length (in)	101.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	2.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	71.0
Yes	PAR 1 Slope %	1.6
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	71.0
No	PAR 2 Slope %	4.5
Yes	PAR 2 XSlope %	0.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.6
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 18960

CATS Stop Description: Tryon St & University City Blvd

CATS Route ID: 11

CATS Route Name: North Tryon

Total Cost: \$ 3150.00

