


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10011751	Main Street: N_TRYON_ST	Cross Street: N/A	Location: W
ADA ID: D0DEA3F00259	Overall Compliance: N/A	Severity Score: 10	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

CATS Stop ID: 45947

CATS Stop Description: Tryon St & Tom Hunter Rd

CATS Route ID: 11, 211

CATS Route Name: Multiple

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	0.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	90.0
Yes	PAR 1 Slope %	1.3
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	120.0
Yes	PAR 2 Slope %	1.3
Yes	PAR 2 XSlope %	0.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.5
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	50.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	0.5
Yes	Clear Floor Space XSlope %	1.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	99.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

