


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                            |                                         |             |
|-----------------------------------------|----------------------------|-----------------------------------------|-------------|
| Intersection ID: 10037397               | Main Street: SCALEYBARK_RD | Cross Street: N/A                       | Location: E |
| ADA ID: D3A40B349DAD                    | Overall Compliance: No     | Severity Score: 25                      |             |
| Codes/Mitigation Info/Possible Solution |                            | Field Measurements/Component Compliance |             |



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Remove & Replace  
Clear Floor Space. Remove or  
Relocate Protruding  
Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.3, 810.2.4,  
810.3, R302, R302.5, R308.1.1.2,  
R404.1, R404.2, R404.3**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 60.0 |
| Yes        | Boarding Area Length (in)       | 96.0 |
| No         | Boarding Area Slope %           | 2.1  |
| Yes        | Boarding Area XSlope %          | 1.9  |
| No         | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 59.0 |
| Yes        | PAR 1 Slope %                   | 1.9  |
| No         | PAR 1 XSlope %                  | 2.1  |
| N/A        | PAR 1 XSlope Location           | Perp |
| No         | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 59.0 |
| No         | PAR 2 Slope %                   | 2.8  |
| Yes        | PAR 2 XSlope %                  | 2.0  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 1.7  |
| N/A        | Shelter                         | No   |
| No         | Clear Floor Space               | Yes  |
| N/A        | Clear Floor Space Shelter       | No   |
| Yes        | Clear Floor Space Width (in)    | 48.0 |
| No         | Clear Floor Space Length (in)   | 40.0 |
| No         | Clear Floor Space Slope %       | 2.2  |
| Yes        | Clear Floor Space XSlope %      | 1.4  |
| N/A        | Alcove Condition?               | Yes  |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 96.0 |
| N/A        | Bench?                          | Yes  |
| No         | Protruding Objects?             | Yes  |

CATS Stop ID: 46280

CATS Stop Description: Scaleybark Rd & Belrose Ln

CATS Route ID: 30

CATS Route Name: Woodlawn Crosstown

Total Cost: \$ 4650.00

