


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 15105	Main Street: N_DOTGER_AV	Cross Street: RANDOLPH_RD	Location: NW
ADA ID: D541CD05D26B	Overall Compliance: No	Severity Score: 85	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2, 810.2.3, 810.3, R302, R302.5, R308.1.1, R404.1

CATS Stop ID: **23690**

CATS Stop Description: **Randolph Rd & Dotger Ave**

CATS Route ID: **15, 62x**

CATS Route Name: **Multiple**

Total Cost: \$ **1850.00**

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	3.8
No	PAR 1 XSlope %	4.1
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	4.1
N/A	Shelter	Yes
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	80.0
N/A	Bench?	No
Yes	Protruding Objects?	No

