


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10029218	Main Street: JOHNSON_AND_WALES_WY	Cross Street: N/A	Location: E
ADA ID: D74096C15C13	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

N/A

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	177.0
Yes	Boarding Area Length (in)	163.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	4.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	71.0
Yes	PAR 1 Slope %	5.2
Yes	PAR 1 XSlope %	1.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	71.0
Yes	PAR 2 Slope %	4.9
Yes	PAR 2 XSlope %	1.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	105.0
N/A	Bench?	No
No	Protruding Objects?	Yes

CATS Stop ID: 59581

CATS Stop Description: Johnson & Wales Way @ Doubletree

CATS Route ID: 40x, 41x, 46x, 48x, 52x, 53x, 61x, 62x, 64x, 65x, 74x, 77x, 82x, 88x

CATS Route Name: Multiple

Total Cost: \$ 2000.00

