


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10017853	Main Street: N_GRAHAM_ST	Cross Street: N/A	Location: W
ADA ID: D757F1A2F1FA	Overall Compliance: No	Severity Score: 100	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Provide Boarding Area. Provide Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions. Adjust Transit Stop Sign Height.

Surveyor Notes:

TEMPORARY TRANSIT STOP DUE TO CONSTRUCTION

PROW/ADA:

302.7, 402.2, 810.2, R302, R308.1.1, R402.3

CATS Stop ID: **40040**
 CATS Stop Description: **Graham St & Sugar Creek Rd**
 CATS Route ID: **22**
 CATS Route Name: **Graham Street**

Total Cost: \$ **3400.00**

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	1.2
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
No	Transit Sign Height (in)	33.0
N/A	Bench?	No
No	Protruding Objects?	Yes

