


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041752	Main Street: WILKINSON_BV	Cross Street: N/A	Location: S
ADA ID: DEBF709BB922	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.2, 810.2.4, R302,
R302.3, R308.1.1.1, R308.1.1.2**

CATS Stop ID: **44080**

CATS Stop Description: **Wilkinson Blvd & Ashley Rd**

CATS Route ID: **5**

CATS Route Name: **Sprinter**

Total Cost: \$ **3450.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	73.0
No	Boarding Area Length (in)	60.0
No	Boarding Area Slope %	2.6
Yes	Boarding Area XSlope %	0.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.5
Yes	PAR 1 Slope %	1.5
Yes	PAR 1 XSlope %	0.1
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.7
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	60.0
Yes	Clear Floor Space Length (in)	57.0
Yes	Clear Floor Space Slope %	1.0
Yes	Clear Floor Space XSlope %	0.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

