


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                        |                                    |                                |              |
|------------------------|------------------------------------|--------------------------------|--------------|
| Intersection ID: 48696 | Main Street: MONTGOMERY_GARDENS_DR | Cross Street: BEATTIES_FORD_RD | Location: NW |
| ADA ID: E2746D06FABF   | Overall Compliance: No             | Severity Score: 15             |              |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**305.2, 810.3, R404.1, R404.2**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 60.0  |
| Yes        | Boarding Area Length (in)       | 144.0 |
| Yes        | Boarding Area Slope %           | 0.5   |
| Yes        | Boarding Area XSlope %          | 0.8   |
| Yes        | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 60.0  |
| Yes        | PAR 1 Slope %                   | 1.2   |
| Yes        | PAR 1 XSlope %                  | 0.1   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| N/A        | PAR 2 Exist?                    | No    |
| N/A        | PAR 2 Width (in)                | N/A   |
| N/A        | PAR 2 Slope %                   | N/A   |
| N/A        | PAR 2 XSlope %                  | N/A   |
| N/A        | PAR 2 XSlope Location           | N/A   |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 1.1   |
| N/A        | Shelter                         | Yes   |
| No         | Clear Floor Space               | Yes   |
| N/A        | Clear Floor Space Shelter       | Yes   |
| Yes        | Clear Floor Space Width (in)    | 60.0  |
| Yes        | Clear Floor Space Length (in)   | 64.0  |
| No         | Clear Floor Space Slope %       | 5.4   |
| Yes        | Clear Floor Space XSlope %      | 0.0   |
| N/A        | Alcove Condition?               | Yes   |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 90.0  |
| N/A        | Bench?                          | Yes   |
| No         | Protruding Objects?             | Yes   |

CATS Stop ID: 42660

CATS Stop Description: **Beatties Ford Rd & Montgomery Gardens Dr**

CATS Route ID: 7

CATS Route Name: **Beatties Ford**

Total Cost: \$ 2500.00

