


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10040690	Main Street: W_MOREHEAD_ST	Cross Street: N/A	Location: NE
ADA ID: E4C3F26CD909	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.4, 810.3, R308.1.1.2,
R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	113.0
No	Boarding Area Slope %	3.9
Yes	Boarding Area XSlope %	0.9
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	54.0
Yes	PAR 1 Slope %	0.6
Yes	PAR 1 XSlope %	1.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	54.0
Yes	PAR 2 Slope %	0.3
Yes	PAR 2 XSlope %	1.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.5
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	55.0
Yes	Clear Floor Space Length (in)	60.0
No	Clear Floor Space Slope %	3.4
Yes	Clear Floor Space XSlope %	0.2
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: **45407**

CATS Stop Description: **Morehead St & Arty Ave**

CATS Route ID: **5**

CATS Route Name: **Sprinter**

Total Cost: \$ **1250.00**

